

Wels, February 16th 2015

CONFORMITY DECLARATION DC SWITCH FRONIUS SYMO

Fronius International GmbH

hereby confirms, that the DC disconnect switch in the inverters

- / **Fronius Symo 3.0-3-S – 4.5-3-S**
- / **Fronius Symo 3.0-3-M – 8.2-3-M**
- / **Fronius Symo 10.0-3-M – 20.0-3-M**

is conform with EN 60947.

Thus this DC disconnect switch fulfils the requirements according to EN/IEC 60364-7-712.

Fronius International GmbH

Solar Energy Division

Froniusplatz 1

A-4600 Wels



DI Thomas Mühlberger

Head of Solution Management